

# EnergyCell PLC Series ADVANCED PURE LEAD CARBON BATTERY

### Three Reasons to Choose the EnergyCell PLC Series from OutBack Power:

#### 1. PURPOSE-BUILT

- Batteries designed for residential or light-commercial off-grid, backup or self-consumption renewable energy power demands
- 3,000 cycles at 50% DOD
- Pure lead extends the life of the battery versus traditional VRLA and allows for increased float capability for backup applications
- Advanced carbon technology reduces the effect of sulfation and is compatible with Partial State of Charge (PSoC) operation

### 2. EASY-TO-INSTALL AND MAINTAIN


- PLC technology means 99% gas recombination efficient, no periodic watering of cells, no re-torquing of terminal connections, and no equalization charge under standard operating conditions
- · Modular space-saving design when installed with IBR rack
- 2 year shelf life
- OPTICS RE connectivity means real-time access to critical battery performance data
- Batteries and power electronics can be installed in the same area\*
- At end of life, lead acid batteries are 96% recyclable
- Full replacement warranty—6 year domestic, 4-5 year global

### 3. SINGLE-BRAND SYSTEM SOLUTION

- Optimized to work seamlessly with OutBack power conversion equipment
- Ease of ordering with SystemEdge package configurations—to learn more visit www.outbackpower.com
- Single point of contact for all technical system inquiries
- Quality and reliability from OutBack Power assures customers receive the best technologies for renewable energy systems in the market today



## **OutBack EnergyCell PLC Series Typical System Integration**:



### OUTBACK POWER—MASTERS OF THE OFF-GRID. FIRST CHOICE FOR THE NEW GRID.



### MAKE THE POWER

- FLEXpower Integrated Systems
- Inverter/Chargers & Charge Controllers



### STORE THE ENERGY

- EnergyCell RE, GH, NC and OPzV Batteries
- Battery Enclosures and Racking



### MANAGE THE SYSTEM

- OPTICS RE System Monitoring and Control
- MATE3 System Display and Communications

OutBack reserves the right to make changes to the products and information contained in this document without notice. Copyright  $\odot$  2018 OutBack Power. All Rights Reserved. OutBack is a registered trademark of The Alpha Group.


1


EnergyCell Models:	200PLC								
Cells Per Unit	6								
Nominal Voltage	12VDC								
<b>Cycle Life</b> (50% DOD, 1.75VPC)	3000								
Absorb Voltage (25°C)¹	14.1VDC								
Absorb Time <sup>2</sup>	6hrs (0.15C)								
Float Voltage (25°C)¹	13.5VDC								
Float Time	6hrs (0.15C)								
Equalize Voltage and Charge Frequency	14.1								
Re-Bulk Voltage³	14.1								
Re-Float Voltage <sup>3</sup>	13.5								
Maximum Charge Current (Per Battery)	40A								
Operating Temperature Range (w/Temperature Compensation)	<b>Discharge</b> : -40 to 149°F (-40 to 65°C) <b>Charge</b> : 5 to 140°F (-15 to 60°C) <b>Storage</b> : -4 to 104°F (-20 to 40°C)								
Optimal Operating Temperature Range	68 to 86°F (20 to 30°C)								
Temp-Comp Factor (Charging)	-4mV per ℃ per cell (2V)								
Self-Discharge Time	Batteries can be stored up to 24 months at 25°C (77°F) before a freshening charge is required. For higher temperatures the time interval will be shorter								
Terminal Type	T11								
Terminal Hardware Initial Torque	11 to 14.7Nm								
Weight (lb/kg)	130/59								
Dimensions H x D x W (in/cm) <sup>4</sup>	12.6 x 22 x 4.92 / 32 x 55.88 x 12.50								
Warranty⁵	Domestic: 6 year full replacement Global: 4-5 year full replacement								
Accessories	Ships with interconnect bars, terminal covers and hardware kit								

**Note:** PC-ABS flame retardant jar and cover to UL94V-0 <sup>1</sup> If using both inverter and charge controller, set the charge controller to 0.4V higher (0.2V for 24V systems) to give the charge controller charging priority. <sup>2</sup> Will always be 2 hours if charge rate is 10% of battery bank amp-hours. For higher or lower charge rates, use the formula AR ÷ (CR x 0.5) = absorb time where AR = amp-hours remaining after absorb voltage is first reached (10% of battery bank Ah) and Cr = amp-hours of current charge.

<sup>3</sup> Default values for 12/24/48V systems. May need to be adjusted for site application. <sup>4</sup>Batteries to be installed with 0.5in (12.7mm) spacing minimum and free air ventilation. <sup>5</sup>See OutBack EnergyCell warranty document for full details.

	12V Ampere Hour Capacity to 1.75 Volts Per Cell at 77°F (25°C)												
Discharge in Hours:	1	2	3	4	5	8	12	20	24	48	100		
EnergyCell 200PLC	104	120	132	140	145	160	168	178	182	191	200		





OutBack reserves the right to make changes to the products and information contained in this document without notice. Copyright © 2018 OutBack Power. All Rights Reserved. OutBack is a registered trademark of The Alpha Group.

2

<sup>\*</sup>Consult local and regional electrical code for proper installation of energy storage requirements.